



**AAMA/WDMA/CSA  
TEST REPORT**

**WINTECH**

**SERIES/MODEL: S325 Window  
PRODUCT TYPE: Out Swing Casement Window**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	C-C70 800 x 1500 (32 x 60)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG70-Size Tested 800 x 1500 (32 x 60)-Type C
Design Pressure	+3360 Pa (70.00 psf)
Operating Force (in motion)	27 N (6.0 lbf)
Air Infiltration @ 1.6 psf	0.05 L/s/m <sup>2</sup> (0.01 cfm/ft <sup>2</sup> )
Water Penetration Resistance Test Pressure	510 Pa (10.50 psf)
Uniform Load Structural Test Pressure	+5040 Pa (105.00 psf)
Forced Entry Resistance	Pass

**Test Completion Date: 11/22/11**

Reference must be made to Report No. QCT11-2333.01, dated 12/21/11 for complete test specimen description and detailed test results.

**QUAST CONSULTING AND TESTING, INC.**

*Exterior Façade/Fenestration Consulting & Testing*

1055 Indianhead Drive • P.O. Box 241 • Mosinee, WI 54455-0241 • Phone: 715-693-TEST (8378) • Fax: 715-693-0689 •  
www.qcandt.com