



**AAMA/WDMA/CSA  
TEST REPORT**

**Rendered to:**

**WINTECH  
201 Industrial Boulevard  
Monett, MO 65708**

**PRODUCT TYPE: Aluminum Fixed Window  
SERIES/MODEL: S325 Fixed**

Title	Summary of Results
AAMA/WDMA/CSA 101/I.S.2/A440-05	F-C70 1500 x 1500 (60 x 60)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW – PG70 1500 x 1500 (60 x 60) – Type F
Design Pressure	3360 Pa (70.0 psf)
Operating Force	N/A
Air Infiltration @ 1.6 psf	<0.05 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
Air Infiltration @ 6.2 psf	<0.05 L/s/m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
Water Penetration Resistance Test Pressure	510 Pa (10.5 psf)
Uniform Load Structural Test Pressure	+5040 psf (105.0 psf)
Forced Entry Resistance	Grade 10

**Test Completion Date: 10/19/2011**

Reference must be made to Report No. QCT11-2330.01, dated 10/20/2011 for complete test specimen description and data.

**QUAST CONSULTING AND TESTING, INC.**

*Exterior Façade/Fenestration Consulting & Testing*

1055 Indianhead Drive • P.O. Box 241 • Mosinee, WI 54455-0241 • Phone: 715-693-TEST (8378) • Fax: 715-693-0689 •  
www.qcandt.com