



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

WINTECH

SERIES/MODEL: S250 Outswing Casement Window

PRODUCT TYPE: Outswing Casement/Fixed/Outswing Casement Window

Title	Summary of Results
AAMA/NWWDA 101/I.S.2-97	C-C50 96 x 60
AAMA/WDMA/CSA 101/I.S.2/A440-05	C-C50 2438 x 1500 (96 x 60)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG50-Size Tested 2438 x 1500 (96 x 60)-Type C
Design Pressure	<u>+2400</u> Pa (50.00 psf)
Operating Force (in motion)	13 N (3.0lbf)
Air Infiltration @ 1.6 psf	0.05 I./s/m ² (0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	730 Pa (15.00 psf)
Uniform Load Structural Test Pressure	<u>+3600</u> Pa (75.00 psf)
Forced Entry Resistance	Pass

Test Completion Date: 10/01/10

Reference must be made to Report No. QCT10-1920.01a, dated 10/14/10 for complete test specimen description and detailed test results.

QUAST CONSULTING AND TESTING, INC.

Exterior Façade/Fenestration Consulting & Testing

1055 Indianhead Drive • P.O. Box 241 • Mosinee, WI 54455-0241 • Phone: 715-693-TEST (8378) • Fax: 715-693-0689 •

www.qcandt.com