



**AAMA/WDMA/CSA
TEST REPORT**

Rendered to:

**WINTECH
201 Industrial Boulevard
Monett, MO 65708**

**PRODUCT TYPE: PVC Fixed Window
SERIES/MODEL: S70 Fixed**

Title	Summary of Results
ANSI/AAMA/NWDA 101/I.S.2-97	F-C30 60 x 60
AAMA/WDMA/CSA 101/I.S.2/A440-05	F-C30 1500 x 1500 (60 x 60)
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW – PG30 1500 x 1500 (60 x 60) – Type F
Design Pressure	1440 Pa (30.0 psf)
Operating Force	N/A
Air Infiltration	0.05 L/s/m ² (0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	220 Pa (4.5 psf)
Uniform Load Structural Test Pressure	+2160 psf (45.0 psf)
Forced Entry Resistance	Grade 10

Test Completion Date: 10/01/10

Reference must be made to Report No. QCT10-1764.01, dated 10/14/10 for complete test specimen description and data.

QUAST CONSULTING AND TESTING, INC.
Exterior Façade/Fenestration Consulting & Testing

1055 Indianhead Drive • P.O. Box 241 • Mosinee, WI 54455-0241 • Phone: 715-693-TEST (8378) • Fax: 715-693-0689 •
www.qcandt.com