

**TEST REPORT****Rendered to:**

WINDOW TECHNOLOGY, INC. – DBA WINTECH
201 Industrial Dr.
Monett, MO 65708

PRODUCT TYPE: Louver
SERIES/MODEL: H200I

Title	Summary of Results
ASTM E330 Design Pressure	± 3600 Pa (75 psf)
ASTM E330 Uniform Load Structural Test Pressure	± 5400 Pa (112.5 psf)
ASTM E1886 & ASTM E1996 – Large Missile Missile D – Windzone 4	± 3600 Pa (75 psf)

Test Completion Date: 09/29/2011

Reference must be made to Report No. QCT11-2263.01, dated 09/30/2011 for complete test specimen description and data.

QUAST CONSULTING AND TESTING, INC.*Exterior Façade/Fenestration Consulting & Testing*

1055 Indianhead Drive • P.O. Box 241 • Mosinee, WI 54455-0241 • Phone: 715-693-TEST (8378) • Fax: 715-693-0689 •
www.qcandt.com