




CONSTRUCTION CONSULTING LABORATORY INTERNATIONAL



WINTECH

201 Industrial Blvd
Monett, MO
417 235-7821

Product Type: HVAC DOOR
Series / Model: SD3200 DOOR
Specification: ASTM E 283, ASTM E 331, ASTM E 330
Report: CCLI 17-060
Test Completion: 04/11/2017

Specimen	Title	Summary of Results
1	Product Size	38" x 72"
	Air Infiltration 20" WC	0.30 L/s•m ² (0.06 cfm/ft ²)
	Water Penetration Resistance	20" or (104.2 psf) or (199.7 mph)

Attachments: This report is complete only when all attachments listed are included.

Appendix A: Complete drawings packet on file with the program administrator and Construction Consulting Laboratory.