


## CONSTRUCTION CONSULTING LABORATORY INTERNATIONAL



## WINTECH

201 Industrial Blvd Monett, MO 417 235-7821

**Product Type:** HVAC DOOR

Series / Model SD4200 IN-SWING Test Completion 04/11/2017

**Specification:** ASTM E 283, ASTM E 331, ASTM E 330

Report CCLI 17-061

Specimen	Title	Summary of Results
1	Product Size	38" x 72"
	Air Infiltration 20" WC	<0.05 L/s•m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
	Water Penetration Resistance (Static)	1.2" or (6.24 psf) or (49.3 mph)

Attachments: This report is complete only when all attachments listed are included.

**Appendix A**: Complete drawings packet on file with the program administrator and Construction Consulting Laboratory.