




# CONSTRUCTION CONSULTING LABORATORY INTERNATIONAL



## WINTECH

201 Industrial Blvd  
Monett, MO  
417 235-7821

**Product Type:** HVAC DOOR  
**Series / Model:** SD4200 DOOR      **Test Completion:** 04/11/2017  
**Specification:** ASTM E 283, ASTM E 331, ASTM E 330  
**Report:** CCLI 17-062

Specimen	Title	Summary of Results
1	Product Size	38" x 72"
	Air Infiltration 20" WC	<0.05 L/s•m <sup>2</sup> (<0.01 cfm/ft <sup>2</sup> )
	Water Penetration Resistance	20" or (104.2 psf) or (199.7 mph)

**Attachments:** This report is complete only when all attachments listed are included.

**Appendix A:** Complete drawings packet on file with the program administrator and Construction Consulting Laboratory.